

**NOTIFICATION OF CHANGE IN BID BEFORE DUE**

RUSSELL DESIGN  
114 Rayson Street, Suite 2A  
Northville, MI 48167

PROJECT: French Landing

LOCATION: Van Buren Township, Michigan

OWNER: Van Buren Charter Township  
46425 Tyler Road  
Van Buren Township, MI

CONTRACT FOR: Park Improvements

BID DUE DATE: **April 14, 2021**

RD JOB NO. V05-201  
ADDENDUM NO. 1

DATE: March 24, 2021

PAGE 1 OF 1

---

This addendum is issued prior to Bid Opening. The following items are changes, additions, elimination's, and/or clarifications of Drawing (s) and/or Specifications and are to be considered by Bidding Contractor in making and submitting Proposal. The Proposal is to include all labor and material required completing items as specified. All items, except Alternates, which depend upon formal acceptance and approval by Owner, are to be considered part of Contract Documents.

**THE BID DUE DATE HAS BEEN EXTENDED TO APRIL 14, 2021 AT 10:00 AM (LOCAL TIME)**

**DRAWING CHANGES:**

Sheet L-3 (Issued)

Enlarged concrete pad from 45 foot diameter to 63 foot diameter  
Modified concrete walk to accommodate larger concrete pad  
Modified layout dimensions to reflect changes  
Added centerline location of tensile structure  
Modified note number 15 to include 3 x 3 concrete pad for trash receptacles (5 locations)

Sheet L-4 (Issued)

Modified concrete jointing to accommodate tensile structure footing locations on larger concrete pad  
Modified concrete jointing on concrete walks due to accommodate larger concrete pad

Sheet L-5 (Issued)

Modified grading of relocated concrete walk and larger concrete pad

Sheet L-6 (Not Issued)

Modified seeded lawn to accommodate the relocated concrete walk and larger concrete pad.

Sheet L-7 (Not Issued)

Modified Detail 4 title to add Tensile Structure Pad

Sheet IR-1 (Not Issued)

Modified irrigation layout to accommodate the relocated concrete walk and larger concrete pad

**STRUCTURAL DRAWINGS FOR THE TENSILE STRUCTURE FOOTINGS, REINFORCEMENT AND EMBEDDMENT REQUIREMENTS ARE FORTHCOMING AND EXPECTED TO BE AVAILABLE ON OR BEFORE: MARCH 31, 2021.**

Page 2.

**SPECIFICATION CHANGES :**

See attached Proposal Form Section 00 41 43 for modified quantities:

1. Added line item for (29) Steeplechase Arborvitae, 8 foot HEAVY

It is the responsibility of Bidder to revise Bid Proposal Form in accordance with the described changes.

library\addendum form